

District Level Laboratory- PHED, Siwan,
Chemical Examination Report of Drinking Water Samples
 Sample collected on Spot by R.B.S. PUBLIC School & Received in the laboratory on Dated 28.04.2020

Sl. No.	District	Block	Gram Panchyat	Village	Name of nearest person/Institution	PARAMETERS EXAMINED (Value in mg/l, except pH, otherwise mentioned)															Remarks
						pH	Turbidity	Conductivity	TDS	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	Arsenic		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
1	Siwan	DARAULI	TARAWA	TARWA PARASIA	R.B.S. PUBLIC SCHOOL TARWA PARASIA	6.90	1	-	187	120	130	24	-	10	800	0.05	BDL	BDL			
Min. - Max. Permissible Limit						4.5 - 8.5	5 N1 - 1		500 - 2000	200 - 600		75 - 200	30 - 100	250 - 1000	200 - 400	0.3 - 1.0	45	1-1.5	0.01		

Remarks: All Parameters are under Permissible Limit. Fit for drinking.
 BDL :- Below Detection Limit

निरयानन्द झा
 Manager
R.B.S. PUBLIC SCHOOL
 Tarwa Parsiya, Darauli (Siwan)

Beetha
 Principal
R.B.S. PUBLIC SCHOOL
 Tarwa Parsiya, Darauli (Siwan)

Hy
 30/04/2020
 Signature of the Chemist P.H. Division
CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
SIWAN